Azadi Ka Amrit Mahotsav

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F.6/DFS/MS/School/2024/SZ/1093 Dated: 05/11/2024

FIRE SAFETY CERTIFICATE

Certified that the **Dr. APJ Abdul Kalam C.B. Senior Secondary School** at DID Line, Shastri Bazar, Delhi Cantt, New Delhi–110010, comprised of ground plus two upper floors, owned/occupied by Delhi Cantonment Board, was issued Fire Safety Certificate by this department vide letter No. F.6/DFS/MS/School/2021/SZ/1025 dated 17/12/2021. The said premises was re-inspected by the officer concerned of this department on dated 21/10/2024 in the presence of Mr. Harsh Sharma (Supervisor) and observed that the said premises/building have deemed complied with the fire prevention and fire safety requirement in accordance with rule 33 of Delhi Fire Service Rules, 2010 and that the building is fit for occupancy class **Group-B** (Educational) with effect from 05/11/**2024** for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 05/11./2024 at New Delhi by

(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

Copy to: -

1. Sh. Kapil Goyal, Office of the Delhi Cantonment Board, Sadar Bazar, Delhi Cantt., New Delhi–110010
2. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi–110054

Conditions for the validity of Fire Safety Certificate:

1. All the means of escape / entry / exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working conditions at all times. Any loss of life or property due to non-functional fire safety measure shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of firefighting system.
4. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3. of UBBL-2016), if any.
5. The owner/occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The foam is available on www.dfs.delhigovt.nic.in.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule37] along with a copy of this Certificate, six months prior to its expiry".